IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dr Hawkins DATE 21 Mar 75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jennings Rd N. to Friendship Church Rd on left (# 1886) approx. ½ mile on left. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Cecil Clay Loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	fair	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to rear of home	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	ok	
			Rock or other impervious formations	ok	

Lot Area _____



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public ( )
water from exterior wall faucet

Installed by Harlee Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: Permission was given to cross property line approx. 2' west the end of the nitrification line by the daughter-in-law. Downspout from gutters and footer drains must be piped across the nitrification line if system is expected to function properly."

CERTIFICATE OF COMPLETION BY Russ Howard DATE 21 Mar 75

(Stubbed out in rear of home rather than on the side of the home.)

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold