HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 13H-A-150.
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: DWAYNE CHRISTIAN OWNER: ✓ AGENT: PHONE: 876-0087
ADDRESS: RT. 1, BOX 16-A OLIN NC 28660 APPLICATION DATE: 2/16/99 DATE EVALUATED: 2/16/99
PROPOSED FACILITY: 3BR D/W MH
PROPERTY SIZE: ~110 x 400' (1.0 ACRE)
LOCATION OF SITE: US 21N, TL JENNINGS, TL RAIDER, 2ND MH ON (L)
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	N 6%	0-24	C	ABK	1:1 / FI	1942 WETNESS CONDITION: S
		24-48	C	SBK	1:1 / FR	1943/ 1956 SAPROLITE: S
						1944 RESTRICTIVE HORIZON: S
						1948 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.35 GPD/FT2
2						1942 WETNESS CONDITION:
						1943/ 1956 SAPROLITE:
						1944 RESTRICTIVE HORIZON:
						1948 PROFILE CLASSIFICATION:
						PROFILE LTAR:
3						.1942 WETNESS CONDITION:
						.1943/.1956 SAPROLITE:
						.1944 RESTRICTIVE HORIZON:
						.1948 PROFILE CLASSIFICATION:
						PROFILE LTAR:
4						.1942 WETNESS CONDITION:
						.1943/.1956 SAPROLITE:
						.1944 RESTRICTIVE HORIZON:
						.1948 PROFILE CLASSIFICATION:
						PROFILE LTAR:
5						.1942 WETNESS CONDITION:
						.1943/.1956 SAPROLITE:
						.1944 RESTRICTIVE HORIZON:
						.1948 PROFILE CLASSIFICATION:
						PROFILE LTAR:

AVAILABLE SPACE (.1945): S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT
OTHER FACTORS(.1946): NONE SYSTEM TYPE: CONV. GRAVITY
EVALUATED BY: STEVE HENNICK OTHER(S) PRESENT: SELENA LINDLEY, DWAYNE CHRISTIAN
COMMENTS:

DRAFT