IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 200372 (B)

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4749934637

APPLICANT: Friendship Holding Corp. APPLICANT ADDRESS: PO Box 280 Cornelius

PHONE: 704-682-1474 ALT. PHONE: N/A

SITE ADDRESS: 1025 Tomlin Mill Rd.

SITE DIRECTIONS: Hwy 21N TL Jennings Rd TR Tomlin Mill Rd.

DESIGN FLOW: 724 gpd L.T.A.R.: 0.25

SUBDIVISION: N/A SECTION: N/A LOT # N/A LOT AREA: 5.56 acres

Septic Tank Existing (gal) STB Date

Pump Tank (gal) PT Date

Pump Make Model Serial #

Nitrification Fields 1 # Lines 2 Linear Ft: 210

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☐ New System ☐ Repair ☑ Expansion System Type: I II (III) IV V VI

System Description: 35% Reduction

Repair System Description: Conventional - Pump

Maintenance Agreement Required: ☐ YES ☑ NO

☑ GRAVITY ☐ PRESSURE

☐ Residence No. Bedrooms

☑ Business No. Persons

☐ Other 4 bath rooms No. Employees 5

☑ Slab ☐ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☑ Public ☐ Community

Comments / Conditions: Permit is approval for Convenient store with 4 public water closets & 5 employees. Install per attached design.
- Submit effluent samples & water readings as described in flow reduction approval. - OP will be held until both Field A & Field B are completed & approved by Health Department ☆

INITIAL SITE SKETCH

See Attached design by:
Piedmont Design Associates P.A.
and
Rollans Soil & Environmental Services P.A.
Field B
Domestic Waste ONLY!

AS BUILT SKETCH

Installed as designed.

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

☐ IMPROVEMENT PERMIT with plat valid without expiration. ☑ IMPROVEMENT PERMIT with site plan valid for 60 mos. ☑ AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: Date: 11/17/14 Installed by: A1 Backhoe

IMPROVEMENT PERMIT by: Justin Henderson Date: 11-17-14 OPERATION PERMIT by: Justin Henderson Date: 1-6-15

AUTHORIZATION TO CONSTRUCT by: Justin Henderson Date: 11-17-14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

1 inch equals 100 feet
Kuser Schultz
pin # 47499346037
* New system must be 20' from all parts of existing system
LENTZ RD
TOMLIN MILL RD
PB 48-111
System = (5) 3' x 10' lines = effluent splitter
Repair
640
459
181
278
205
261
233
220
199
293
381
295
40
890
880
265
391
124
870
900
N
S
E
W