IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Terry Harris DATE 6/13/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-77N, T.L on Tomlin Mill Rd, T.R. on 1st dirt Rd # 1975 Mobile Home on Lft S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	none	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	unk	
			Rock or other impervious formations	none observed	

Lot Area acreage



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Self

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 6/13/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold