DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Eddie Messer Cup APPLICANT: Same
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 7/26/01
PROPOSED FACILITY: 3BR H w/ Pool PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 38 Acres
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	Flat 4%	0-13	LS g	NS NP NE	10YR 5/6				PS .3
		13-24	scl wk	SS NP SE					
		24-48+	c/cc sbk	FI	Lots of CC				
2	Linear 6%	0-18	ls	NS NP NE					PS .3
		18-23	scl sbk	SE	32" 10YR 7/2		LS to PS w/2 shallow system 20" deep		
		23-48	cl	FI FI SE	36" 7.5YR 8/2				
					45"+ 7.5YR 8/0				
3	Up 8%	0-14	LS g	NS NP VF					PS .35
		14-30	scl wk	SS NP SE					
		34-45	sc g	VF VP NE					
		45	cl		45 Cm 2				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Shallow, Standard Trench	Shallow, Standard Trench
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____