4750 44 63460

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Doris H. Houston DATE Oct. 16, '89 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115-21 No. TR 2375 (Houston Rd.) on left approx ¼ mile before jct w/ 2390 (Westmoreland Rd.) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other System replacement

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	20 ↓	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2%	
Site ~~Suitable~~ PS	Yes ( )	No ( )	Depth to Water Table	6'+	
			Rock or other impervious formations	none obs.	

Lot Area 3 Ac +

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by James Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DBH

COMMENTS: According to owner & realtor, plumber has appointment to tie straight piped washer and sink drain into main plumbing on Oct 17, 1989. Old system removed within 150' of well.

CERTIFICATE OF COMPLETION BY _____ DATE 10-16-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold