4750502933

10149

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Earl Bowers DATE 9/21/89 PERMIT NO. 4F-B-10

PHONE: Business _____ Home 597-7926

LOCATION 21 N. Turn R. on Houston Rd. On Left ~ 1/2 mile Off Rd in corner of Dunwoody in field. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Clayey
Percolation Rate 49pd/ft²
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations none obs

Lot Area 1 ACRE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System NOT TO SCALE

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Richard Abernathy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

MENTS PERMIT BY R.R. Pierce

The proposed / existing CARPORT addition does not appear to impact the existing septic system.
**NOTE: ALREADY CONSTRUCTED
Wesley Sparks R.S.
Date: 4/20/09
ICHD-Environmental Health Division

N BY Andre C. Pierce, R.S. DATE 9/21/89

DATE _____

OMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
anges are made in installation of system and/or if any false information is supplied in making

py: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

#10149

B-18

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Earl Bowers DATE 7-3-89 PERMIT NO. _____

PHONE: Business _____ Home 597-7926

LOCATION 21 N. Turn Right on Houston Rd. Left on Dunwoody .5mi on Right in Field

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit Yes ( ) No (X)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1 acre

Character & Porosity of Soil Clayey


Percolation Rate .4

Topography 2-6%

Depth to Water Table 10 ft +

Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual X

Public ( )

Installed by _____

I understand and agree to install septic tar system as specified on this Improvemer Permit.

Signed: Earl Bowers

IMPROVEMENTS PERMIT BY Richard Price & P.C. Moore R.S.

COMMENTS: Locate Well 100 ft from Septic System

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIO

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold