IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 14797 PIN# 4750609853 Kathleen w/SAME DATE 1-25-08

OWNER OR APPLICANT Pilot Development Adam's Home PHONE: Business 704 942-1250 Home

ADDRESS 132 Joe V Knox Mooresville NC 28117

LOCATION Hwy 21 N TR Shepherd's Rd TL Houston Rd TL Colonial Congress TR Mills Plantation

SUBDIVISION GA Mills Plantation BLOCK / SECTION LOT 22 LOT AREA .729 Acre SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. .3

Septic Tank: 1060 Gallons: STB 825 Date 6-23-10

Pump Tank: 1000 Gallons: PT 502 Date 6-18-10

Pump Make: ZOELLER Model M140 Serial No.

Nitrification Field: No Fields 1 Square Feet 540 Linear Feet 270'

No Lines 5 Trench Width 24" min Max Trench Bottom Depth 36"

[X] New System [ ] Repair [ ] Expansion System Type: I II III IV V VI

System Description: Pump-Up-Panel Block

Repair System Description: Same

Maintenance Agreement Required: [X] Yes [ ] No

[X] House/Mod. Home [ ] Mobile Home [ ] Business [ ] Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: [X] Individual [ ] Public [ ] Community

Gravel Depth N/A [ ] Gravity [X] Pressure [ ] Slab [X] Crawl Space [ ] Basement w/plumbing [ ] Basement wo/plumbing

Comments:/Conditions: Note: Initial Septic DrainField & Repair Offsite on Easement-22A Initial Site Evaluation by Kathleen Saunders w/ SAME

Comments:/Conditions: Use In line filter in PT 5/27/10 Reviewed Floor plan & Site plan; in compliance with original plan.

INITIAL SITE SKETCH

See Specs. from attached Approved plan by SAME

AS BUILT SKETCH

SET 2FT Pressure Head

INSTALLED AS SHOWN ON ATTACHED LAYOUT RA

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration [ ] Improvement Permit with site plan valid for sixty months [ ] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 2/14/08 Installed by: Rowan Septic

Improvement Permit by: RS date 1/25/08 Operation Permit by: REHS date 9-14-10

Authorization to Construct by: REHS date 5/27/10 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK