DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Georgia Mills Plantation
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): _____ DATE EVALUATED: _____
LOCATION OF SITE: Lot 22 PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
W 1	L	0-5	mo GR SL	FR SS/NP	Br				
		5-33	mo SBK C	FR SS/SP	Red, f-c 1br		f sap	f-chr 2	
		33-48	wk SBK C	FR SS/SP	Red, f-c 1br		f-sap		US
W 2	L	0-4	mo GR SL	FR SS/NP	Br				
		4-19	wk SBK SL	FR SS/SP	Red, f mica		f sap		
		19-43	mo SBK C	FR SS/SP	Red		c-sap		2.3
		43-48	wk SBK CL	FR SS/SP	Red				
W D	L	0-3	mo GR SL	FR SS/NP	Br				
		3-26	mo SBK C	FR SS/SP	Red, f-c 1br, f-c sap				
		26-49	wk SBK C	FR SS/SP	Red, c-1 1br, f-2 chroma		c-m sap		US >26"
22-1	Bt	0-20	wk/mo SBK C	FR SS/SP	Red		F sap		
	CB	20-30	MA 4/FSL SAP	FR SS/SP	multi, F CL pockets				
L	C	30-55	MA 5/4/L SAP	FR SS/SP	multi				0.4

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ailable Space (.1945)		
tem Type(s)		
LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____
MENTS: _____