2 30 pm

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 146390 PIN# 4750619373 DATE 11-20-07

OWNER OR APPLICANT Pilot Developers PHONE: Business 704-202-1524 Home

ADDRESS 132 Joe V Knox Ave Suite 102 Mooresville NC 28117

LOCATION Hwy 115 N TR Shepherd TL Houston TL Colonial Congress TR Mills Plantation across road at tee

SUBDIVISION Georgia Mills Plantation SECTION LOT 19 LOT AREA .74 Ac SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .3gpd/ft²

Septic Tank: 1000 Gallons: STB 825 Date 7/28/09

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1206 Linear Feet 402

No Lines 3@134' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA ☒ Gravity ☐ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI

System Description: 2570 reduction gravity

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons 8 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Shave all berms

Comments:/Conditions: Final Inspection Installed 10/20/09

INITIAL SITE SKETCH

See plan from S&ME

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date Installed by: Rowan Septic Tank

Improvement Permit by: date 11-20-07 Operation Permit by: Wesley Sparks REHS date 10/20/09

Authorization to Construct by: date 8/14/09 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK