2, 30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 146388 PIN# 4750619648 DATE 12-21-07

OWNER OR APPLICANT Pilot Developers/Adams Homes PHONE: Business 704-202-1524 Home

ADDRESS 132 Joe V Knox Ave Suite 102 Mooresville NC 28117

LOCATION Hwy 115 N TR Shepherd TL Houston TL Colonial Congress TR Mills Plantation TR into cul-de-sac

SUBDIVISION Georgia Mills Plantation SECTION LOT 17 LOT AREA 1 Ac SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .3gpd/ft2

Septic Tank: 1000 Gallons: STB 825 Date 4-10-08

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 25% reduction gravity

Repair System Description: 25% reduction gravity

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons 8 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☒ Gravity ☐ Pressure ☒ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Well 100' from system

* Before AC: Plan submitted showing drainage through landscape berm

Plan Submitted gm

INITIAL SITE SKETCH

see plan from 54 ME

Comments:/Conditions:

Raised slab

Discussed w/ Adams Homes about getting plumbing to tank

2-13-08 gm

AS BUILT SKETCH

Installed Quick 4 as shown except ran supply line btw house & Drainfield

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date

Improvement Permit by: Judy Melville date 12-21-07

Authorization to Construct by: Judy Melville date 2-13-07

Installed by: Rowan Septic KS

Operation Permit by: Maria date 5/30/08

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK