DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: GA Mills
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): _____ DATE EVALUATED: 11/2/07
LOCATION OF SITE: Lot 1 PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1949 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
2	22 L 5%0	0-5	wk sbk scl	FR SS/SP	Br Red				
		5-23	mo sbk c	FR SS/SP	Red, f-mica				
		23-42	wk sbk c	FR SS/SP	Red, c-mica	f-c sap			
		42-55	MA sa/sap	FR SS/WP	Mottled	fic packets			23
3	23 on Lot 2 L	0-5	wk sbk scl	FR SS/SP	Br Red				
		5-31	mo sbk c	FR SS/SP	Red, f mica				
		31-57	wk sbk cl	FR SS/SP	Red, C-mica	f-c sap			a.3
(3)		0-12	mo sbk scl	fr sss p	Br				
		12-26	mo sbk c	fr sss p	Red				
		26-45	mo sbk/sbk c	fr sss p	Red	c-yel/br.			.25
		45-53	wk sbk cl	fr sss p		c-sap			
(4)		0-12	wk sbk cl	fr sss p	Br				
		12-45	mo sbk/sbk c	fr sss p	Red	c-yel/br	f-chroma3 f-sap		.225
		45-55	wk sbk cl	fr sss p	Red	f-sap	f-yel/br		

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ilable Space (.1945)		
m Type(s)		
.TAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Karen Wallace
OTHER(S) PRESENT: _____

IENTS: _____