IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 20150

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4750699690

APPLICANT: David Close APPLICANT ADDRESS: 110 Kendall Rd Troutman NC 28166

SITE ADDRESS: 110 Kendall Rd Troutman NC 28166 PHONE: 704-528-5516 ALT. PHONE: N/A

SITE DIRECTIONS: Amity Hill Rd to Oswalt Mill Rd on Overcash Rd to Kendall

SUBDIVISION: N/A SECTION: N/A LOT # N/A LOT AREA: 4 acres DESIGN FLOW: 360 L.T.A.R.: 0.3

Septic Tank 1000 (gal) STB 825 Date 2-3-14

Pump Tank (gal) PT Date

Pump Make Model Serial #

Nitrification Fields 1 # Lines 4 Linear Ft: 270

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☐ New System ☑ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 25% Reduction

Repair System Description: N/A

Maintenance Agreement Required: ☐ YES ☒ NO

☑ GRAVITY ☐ PRESSURE


☒ Residence ☐ Business ☐ Other ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

No. Bedrooms 3 No. Persons 6 No. Employees


Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: Setback Variance approved 1/31/14 with the following conditions: Trench must be 36" deep. Gravel must be placed under and around pipe. Gravel must be covered with a permeable material. Soil must be placed over gravel and pipe. Trench must be covered with 12" of soil. Curtain drain must be installed on uphill side of trench.

INITIAL SITE SKETCH



AS BUILT SKETCH



Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Applicant Signature: Date: 3/3/14 Installed by: Rowan Septic

IT PERMIT by: Date: 03/03/14 OPERATION PERMIT by: APPROVED APR 22 2014 Date:

AUTHORIZATION TO CONSTRUCT by: Date: 03/03/14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK