IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 149421 PIN# 4750706357 DATE 5-21-08

OWNER OR APPLICANT Pilot Development Adams Homes PHONE: Business 704-942-1250 Home Kathleen Stme

ADDRESS 132 Joe V Knox Ave. Suite 102 Mooresville NC 28117

LOCATION 115, TR Shepherds, TL Houston, TL Colonial Congress, TL Mills Plantation

SUBDIVISION Georgia Mills BLOCK / SECTION ____ LOT 29 LOT AREA .7748 SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .25

Septic Tank: 1050 Gallons: STB 825 Date 11-28-09

Pump Tank: 1000 Gallons: PT 302 Date 11-02-09

Pump Make Zoeller Model M153 Serial No. ____

Nitrification Field: No Fields 1 Square Feet 640' Linear Feet 320'

No Lines 5 Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth — ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: LPPPBPS

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons ____ No. Employees ____

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Place wells as shown to meet setbacks 10/23/09 Reviewed Floor plan & site plan, In Compliance with original plan & permit.

Comments:/Conditions: 1/13/2010 Tanks, lines & pressure

INITIAL SITE SKETCH

SEE PLAN From S+ME

AS BUILT SKETCH

The proposed / existing Storage Building addition does not appear to impact the existing septic system.

**NOTE: Shall be min. 5' from septic fields

See Attached Site Plan

Judy Melville R.S.

Date: 3-14-13

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: ____ date 5/21/08 Installed by: Rowan Septic

Improvement Permit by: ____ date 10/23/09 Operation Permit by: ____ REHS date 3-8-10

Authorization to Construct by: ____ date 10/23/09 Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK