11:30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 149425 PIN# 4750707377 DATE 5-21-08

OWNER OR APPLICANT Pilot Development/Adams Homes PHONE: Business 704-942-1250 Home Kathleen STME

ADDRESS 132 Joe V Knox Ave Suite 102 Mooresville NC 28117

LOCATION 115, TR Shepherds, TL Houston, TL Colonial Congress, TL Mills Plantation, on L

SUBDIVISION Georgia Mills BLOCK / SECTION LOT 30 LOT AREA .75Ac SITE CLASS PS DESIGN FLOW 480 L.T.A.R. .25

Septic Tank: 1000 Gallons: STB 825 Date 10-7-09

Pump Tank: 1000 Gallons: PT Date

Pump Make: Zoeller Model 152 Serial No.

Nitrification Field: No Fields 1 Square Feet 640' Linear Feet 320'

No Lines 3 Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth — ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: LPPPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☐ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: Place wells where shown to meet setbacks / Remove berm & terraces Filter in ST

Comments/Conditions: Floor plans reviewed by Kyle Baker and Maria Dotson on 2/26/10. no plumbing in bonus room as indicated on plans (attached) Driveway located on left side of house. maintain all setback requirements.

INITIAL SITE SKETCH

See Plan from STME

AS BUILT SKETCH

4/15/2010 Checked Tanks & lines installed as Drawn Set 2ft pressure head.

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 5/27/08

Improvement Permit by: date 5-21-08

Authorization to Construct by: Kyle Baker, REHS date 2-26-10

Installed by: Brian Septic

Operation Permit by: RCMS date 5-18-10

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK