IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 146381 PIN# 4750710744 DATE 11-20-07

OWNER OR APPLICANT Pilot Developers (Adams Homes PHONE: Business 704-202-1524 Home

ADDRESS 132 Joe V Knox Ave Suite 102 Mooresville NC 28117

LOCATION Hwy 115 N TR Shepherd TL Houston TL Colonial Congress TR Mills Plantation TR to end of cul-de-sac

SUBDIVISION Georgia Mills Plantation SECTION LOT 16 LOT AREA .85 Ac SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .25 gpd/ft²

Septic Tank: 1000 Gallons: STB 125 Date 4/2/08

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1440 Linear Feet 480

No Lines 5 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 25% reduction gravity

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons 8 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☒ Gravity ☐ Pressure ☒ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Shave all berms
System 100'+ from well
Do not place supply line across repair area.

Comments:/Conditions: Raised slab
Discussed w/ Adams Homes about getting plumbing to tank 2-13-08pm

INITIAL SITE SKETCH

See plan from SAME

AS BUILT SKETCH

The proposed / ~~existing~~ Accessory Building addition does not appear to impact the existing septic system.

**NOTE: See attached site plan

Judy Melville REHS

Date: 9-17-10

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date

Improvement Permit by: Judy Melville date 11-20-07

Authorization to Construct by: Judy Melville date 2-13-08

Installed by: Rowan Septic Tank

Operation Permit by: Wesley Sparks RS. date 5/22/08

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK