IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

10:30

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 146367 PIN# 4750712404

OWNER OR APPLICANT Pilot Development / Adams Homes PHONE: Business _____ Home _____ DATE 11-19-07

ADDRESS 132 Joe V Knox Ave Suite 102 Mooresville NC 28117

LOCATION Hwy 115 N TR Shepherd Rd TL Houston TL Colonial Congress TR Mills Plantation on right

SUBDIVISION Georgia Mills Plantation BLOCK / SECTION _____ LOT 13 LOT AREA .75Ac SITE CLASS PS DESIGN FLOW 480gpd L.T.A.R. .3gpd/ft²

Septic Tank: 1000 Gallons; STB 385 Date 2-8-08

Pump Tank: 1000 Gallons; PT 302 Date 4-2-08

Pump Make: Zoeller Model N152 Serial No _____

Nitrification Field: No Fields 1 Square Feet _____ Linear Feet 270

No Lines 5 Trench Width 24" min. Max Trench Bottom Depth 36" Gravel Depth NA ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons 8 No. Employees _____

Water Supply: ☒ Individual ☐ Public ☐ Community

☒ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: Shave all berms
System 100' + from well
Use in-line pump filter such as simtech

Comments/Conditions: ↳ Raised slab
Discussed w/ Adams Homes about getting plumbing to tank
3/16" hole drilled. 2-17-08 dm

INITIAL SITE SKETCH

See plan from SAME

* Note: House was occupied prior to Elect & Alarm Checked by ICHD

AS BUILT SKETCH

5/22/08 Checked Tanks, lines & pressure
4/28/11 Elect. by Jim
4/15/11 Alarm checked

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____

Improvement Permit by: _____ date _____

Authorization to Construct by: _____ date 11-19-07 _____ date 2-13-08

Installed by: Rowan EPTC

Operation Permit by: _____ date 5/3/11

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK