IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECT.

PERMIT# 146394 PIN# 4750715202 DATE 11-26-07

OWNER OR APPLICANT ~~Pilot Developers~~ ADAMS HOME PHONE: Business 704-202-1524 Home

ADDRESS 132 Joe V Knox Ave Suite 102

LOCATION Hwy 115 N TR Shepherd Rd TL Houston TL Colonial Congress TR mills Plantation immediately on left

SUBDIVISION Georgia Mills Plantation SECTION LOT 57 LOT AREA .77Ac SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .25 gpd/ft2

Septic Tank: 1000 Gallons: STB 825 Date 11-5-09

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1440 Linear Feet 480

No Lines 5 @ 96' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 25% reduction gravity

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons 8 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Shave Berms

Comments:/Conditions: Note: Some wet areas on lot but trenches were dry when installed.

INITIAL SITE SKETCH

See plan from SAME

AS BUILT SKETCH

Installed as Drawn

Used "Quick 4"

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date

Improvement Permit by: date 11-26-07

Authorization to Construct by: date 11/17/09

Installed by: Rowan Septic

Operation Permit by: REHS date 2/11/2010

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK