2130

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 146391 PIN# 475871616162 DATE 11-20-07

OWNER OR APPLICANT Pilot Developers/Adams Bld. PHONE: Business 704-202-1524 Home

ADDRESS 132 Joe V Knox Ave Suite 102 Mooresville NC 28117

LOCATION Hwy 115N TR Shepherd TL Houston TL Colonial Congress TL Mills Plantation immediately on Rt

SUBDIVISION Georgia Mills Plantation SECTION LOT 41 LOT AREA .81 Ac SITE CLASS. Ps DESIGN FLOW 480gpd L.T.A.R. .3gpd/ft²

Septic Tank: 1000 Gallons: STB 825 Date 9-1-09

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 5@80' Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 25% reduction gravity

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons 8 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

Gravel Depth NA ☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Shave berms to shed water

Comments:/Conditions: Installed Quick 4 as Drawn

INITIAL SITE SKETCH

See Plan from SAME

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date

Improvement Permit by: date 11-20-07

Authorization to Construct by: RS date 7-30-09

Installed by: Rowan Septic

Operation Permit by: date 10/19/09

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK