IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOO[illegible]LLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 146719 PIN# 4750717619 DATE 11-29-07

OWNER OR APPLICANT Pilot Developers / Adams Homes PHONE: Business 704-202-1524 Home

ADDRESS 132 Joe V. Knox Ave. Suite 102

LOCATION Hwy 115 N TR Shepherd TL Houston on left at corner Colonial Congress

SUBDIVISION Georgia Mills BLOCK / SECTION LOT 9 LOT AREA .785 Ac SITE CLASS PS DESIGN FLOW 480gpd L.T.A.R. .275gpd/Ft²

Septic Tank: 1000 Gallons: STB 825 Date 2/08/08

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1320 Linear Feet 440

No Lines 5 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 25% reduction gravity

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons 8

☐ Business No. Employees

☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Install at 36" trench bottom
Place ST 5' from rear of house
Place well 100' from system
House setback 50' from Houston Rd.

Comments:/Conditions: 27, 27, 27, 28

INITIAL SITE SKETCH

See plan from SAME

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date

Improvement Permit by: Judy McAuliffe date 11-29-07

Authorization to Construct by: Judy McAuliffe date 2-19-08

Installed by: Rowan Septic Tanks

Operation Permit by: Wesley Sparks RS date 4/17/08

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK