4750 796 914

9598

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Michael Redfield DATE Jan 17, '90 PERMIT NO. 4K-2-A-122

PHONE: Business _____ Home _____

LOCATION 115-21 N. TR 1001 (Amity-Ostwalt Rd.) TR 2378 (Overcash Rd.) TL into Windbrook 3rd lot on left S. R. No. _____


SUBDIVISION NAME Windbrook LOT NO. 3 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	ps clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	2-4	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-4a	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4+	
Lot Area	~3/4 Ac.		Rock or other impervious formations	none obs.	

___ Basement with Plumbing ___ Basement without Plumbing ___✓___ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 90 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Signor

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE Jan 17, '90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold