4750798720

9901

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Lovell DATE 5/2/89 PERMIT NO. 18B

PHONE: Business _____ Home 532-6525

LOCATION 21 N. TR Amity Ostwalt TR Overcash
TL Windbrook 2nd on R S. R. No. _____

SUBDIVISION NAME Windbrook LOT NO. 16 SECTION OR BLOCK NO. _____
Barringer 4K2-A-16


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	.39pd	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Rolling	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+	
			Rock or other impervious formations	none	

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Dellinger

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Andrew C. Price

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew C. Price DATE 5/12/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold