47507 99938

100ft

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William F. Jonoson DATE 8/3/89 PERMIT NO. 4K-2-A-14

PHONE: Business _____ Home 372-3010

LOCATION 21 N. TR Amity Ostwalt TR Overcash TL Windbrook On R ~ 4th lot. S. R. No. _____

SUBDIVISION NAME Windbrook LOT NO. 14 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Clayey (loamy)
Percolation Rate .35gpd/1ft²
Topography Slo
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System NOT TO SCALE

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Wayne Ellen

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Andre C. Pierce

COMMENTS: Well is drilled (shown on diagram)

CERTIFICATE OF COMPLETION BY Andre C. Pierce, R.S. DATE Aug. 8, 1989

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold