3:30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 150329 PIN# 4750801316 DATE 5-21-08

OWNER OR APPLICANT ~~Pilot~~ Development ADAMS HOMES PHONE: Business 704-942-1250 ~~Home~~ Kathleen STME

ADDRESS 132 Joe V Knox Ave' Suite 102 Mooresville NC 28117

LOCATION 115, TR Shepherds, TL Houston, TL Colonial Congress, TL Mills Plantation, on L

SUBDIVISION Georgia Mills BLOCK / SECTION ____ LOT 32 LOT AREA 1.09 AC SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 825 Date 2-20-10
Pump Tank: 1000 Gallons; PT 502 Date 2-14-10
Pump Make: ZOELLER Model N152 Serial No. 14MP
Nitrification Field: No Fields 1 Square Feet 640' Linear Feet 320'
No Lines 3 Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth ____

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: LP PPBPS
Repair System Description: LP PPBPS
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other
No. Bedrooms 4 No. Persons ____ No. Employees ____

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Place well as shown to meet set backs / Remove all burms

Comments:/Conditions: CHECKED OFFSITE SUPPLY LINES 3-19-10 STOP UP PAINTED ORANGE

INITIAL SITE SKETCH

SEE Plan From STME

IRED-Environmental Health Division

The proposed / ~~existing~~ Pool addition does not appear to impact the existing septic system.
**NOTE: Pool shall be min. 15' from septic tank/pump tank & 10' from supply line Judy Melville R.S. Date: 7-2-12
IRED-Environmental Health Division

AS BUILT SKETCH

INSTALLED AS SHOWN

105'
105'
110'

SPLIT FED

3 VALVES TOTAL

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: ____ date 5/22/08 Installed by: ROWAN SEPTIC

Improvement Permit by: R-A-Allen REHS date 5-21-08 Operation Permit by: R-A-Allen REHS date 6-11-10

Authorization to Construct by: R-A-Allen REHS date ____ Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK