owes 515.00 4750-80-2586 130

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 150338 PIN# 4750802409.000 DATE 6/2/08

OWNER OR APPLICANT Adams Homes PHONE: Business 704 202-4964 Home

ADDRESS 172 Allendale Cir. Troutman NC 28166

LOCATION 21 N TR Houston Rd. TR Colonial Cinerss TL Mills Plantation on Left

SUBDIVISION Georgia Mills Plantation BLOCK / SECTION LOT 33A LOT AREA .89 SITE CLASS PS DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 825 Date 4-15-10

Pump Tank: 1000 Gallons; PT 302 Date 3-9-10

Pump Make: Zoeller Model N152 Serial No.

Nitrification Field: No Fields 1 Square Feet 1206 Linear Feet 402'

No Lines 3@134 Trench Width 36 Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☑ Pressure ☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☑ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: Pump to PM 25' Reduction

Repair System Description: LP PUMPS

Maintenance Agreement Required: ☐ Yes ☑ No Initial

☑ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☑ Individual ☐ Public ☐ Community

Comments:/Conditions: * Per plan specs
Pump to offsite easement Lot 33A
2 inch Supply line installed

INITIAL SITE SKETCH

See Plumbing S&ME

Comments:/Conditions: 11/2/2010 Checked lines, installed as shown
2ft pressure set 7/15/2010
7/15/2010 Set pressures Checked tanks

AS BUILT SKETCH

3-11-10 CHECKED ELECTRICAL & ALARM

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☑ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 6/2/08

Improvement Permit by: Anthony O'Neil date 6/2/08

Authorization to Construct by: REHS date

Installed by: Rowan Septic

Operation Permit by: REHS date 8-13-10

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK