DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: GA Mills
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ DATE EVALUATED: 3/11/08
LOCATION OF SITE: Lot 34 PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1949 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1	T3-2 AH L	0-4	Mo GR SL	FR ns/np	Br				0.3 PS
		4-18	Mo SBK C	FR SS/SP	Red				
		18-30	WK SBK CL	FR SS/SP	Red		F sap		
		30-36	WK SBK scl	FR SS/SP	Red yel		C sap		
		36-48	MA L sap	FR SS/NP	yel Red				
2	AH B L	0-12	WK SBK scl	FR SS/SP	Red Br		C sap		0.35 - 0.4 PS
		12-48	MA SL sap	FR SS/NP	multi				
3	T3-4 AH L	0-3	Mo GR SL	FR ns/NP	Br				0.3 PS
		3-12	Mo SBK C	FR SS/SP	Red		F sap		
		12-24	WK/Mo SBK CL	FR SS/SP	Red		C sap		
		24-32	WK SBK SCL	FR SS/SP	Red yel		C/M sap		
		32-48	MA SL sap	FR ns/np	Yel Red				
	AH A LCC Bottom of Eroded Area	0-18	WK SBK CL	FR SS/SP	Red		F/C sap		0.3 PS
		18-24	WK SBK CL	FR SS/SP	Red		F CL inc to 30"		
		24-48	MA L sap	FR SS/SP	multi				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
ailable Space (.1945)		
tem Type(s)		
LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Kathleen 3/11/08
OTHER(S) PRESENT: Patrick M.

MENTS: _____

DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: GA Mills
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ DATE EVALUATED: 3/21/08
LOCATION OF SITE: Lot 3-19 PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1	Pit 14 L	0-16	Mo SBK C	FR SS/SP	Red		C sap		0.3
		16-48	wk SBK CL/SCL	FR SS/SP	Red				
2	AB#1								
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
vailable Space (.1945)		
ystem Type(s)		
e LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

MMENTS: _____

DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: _____ DATE EVALUATED: 5/31/08
LOCATION OF SITE: GA Mills Lot 37 PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	AB #1	0-12	mSbkC		Com mi Ca				PS
		12-18	wSbkCL	Pr SSSp Sap					
		18-33	wkSbkCL	vfr nS np	Sap				0
		33-48	massSapSL	fr nS np					
2	Pit 34-1	0-6	mGrSL	vfr SS np					PS
		6-24	mAbkC	fr SS sp					.3
		24-47	wkAbk/SbkC	CL fr SS sp	Com Sap				≥36
		47-54	wkSbkCL	fr SS sp	Many L Sap				
3	14	0-16	mSbkC	Fr SS SpSap					PS
		16-32	wSbkSCL	fr SS SpPlexp					.35
		32-48	wSbkSCL	fr SSS, Sap	Com Sap				
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1943): _____
EVALUATED BY: Anthony Collins
OTHER(S) PRESENT: _____