IREDELL COUNTY HEALTH DEPARTMENT

3:00

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 137197

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4750 81 1582

APPLICANT: Adams Homes APPLICANT ADDRESS: 10115 Kincey Ave. Ste 160 Charlotte 28078

SITE ADDRESS: 706 Houston Rd Troutman 28166 PHONE: ALT. PHONE:

SITE DIRECTIONS: 115 N TR Shepherd Rd TL Houston Rd on left

SUBDIVISION: Georgia Mills SECTION: LOT # 61 LOT AREA: .801 Ac. DESIGN FLOW: 480 gpd L.T.A.R.: .3 gpd/ft²

Septic Tank 1000 (gal) STB 8.25 Date 8-1-13

Pump Tank (gal) PT Date

Pump Make Model Serial #

Nitrification Fields 1 # Lines 3 Linear Ft: 400

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: 2590 Reduction Gravity

Repair System Description: LP 2590 Reduction

Maintenance Agreement Required: ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☒ Slab ☐ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☐ Community

Comments / Conditions:

House foundation shall be at elevation to allow for gravity system

INITIAL SITE SKETCH

See Plan From Michael Athanas & Assoc. Approved by ICHD

AS BUILT SKETCH

INSTALLED AS SHOWN QUIK 4

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 4-18-13 Installed by: Rowan Septic

IMPROVEMENT PERMIT by: Date: 4-17-13 OPERATION PERMIT by: Date: 9-17-13

AUTHORIZATION TO CONSTRUCT by: Date: 4-17-13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK