4750-88-6646

14282

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Craven Ventures Inc. DATE 4/8/92 PERMIT NO. 46-4-A-8

PHONE: Business 845-8824 Home

LOCATION Overcash Rd - 115 N TR on O-A TR on Overcash n 1/2 mile on (L)

SUBDIVISION NAME Pleasant Run S.R. No.

LOT NO. 8 SECTION OR BLOCK NO.

House ☑ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 20,000 FT2

Soil Characteristics P - wk (SS)


Application Rate .3

Topography 2%

Depth to Water Table >48"

Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4 @ 100' X 3'

Sq. Ft. 1200 Linear Ft. 400

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐

Installed by Rowan Septic Tank

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed:

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Aws

COMMENTS

Do not drive or park over drainfield area

No well drilled yet.

CERTIFICATE OF COMPLETION BY Wesley Sparks RS. DATE 4/8/92

EXISTING SYSTEM CHECKED BY DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold