4750890704

11451

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rodney Ramsey DATE June 5, 1990 PERMIT NO. 4K-A-35

PHONE: Business _____ Home _____

LOCATION 2 IN TL 1001 TR Overcash On left in Windbrook Subdivision On right behind 1st trailer on right S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site ~~Suitable~~ PS	Yes ( )	No ( )	

Character & Porosity of Soil PS clay

Percolation Rate 35


Topography 1-5%

Depth to Water Table +3'

Rock or other impervious formations none obs

Lot Area 1 ac

_____ Basement with Plumbing 2 ea 8x8 Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 5
Sq. Ft. 1050 Linear Ft. 350
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by William Crutchfield

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Overcash

Well

IMPROVEMENTS PERMIT BY SCI

COMMENTS:

Well not installed at time ← Windbrook

Permit issued.

Grade on lines to be checked 6-18-90 (well down)

CERTIFICATE OF COMPLETION BY D. R. Harmon, EHS DATE 6-18-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold