4150-89-2061

14391

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Crown Ventures Inc. DATE 5/7/92 PERMIT NO. 46-4-A-3

PHONE: Business _____ Home 845-8824

LOCATION Overcash Rd.

S.R. No. _____

SUBDIVISION NAME Pheasant Run LOT NO. 3 SECTION OR BLOCK NO. _____

House ☐ Mobile Home ☑ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area ~.5 AC

Soil Characteristics P cl TRANS.


Application Rate P .3

Topography P - 2%

Depth to Water Table 5 >48"

Rock or other impervious formations 5 - None observed

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 6 @ 70, 67, 60, 67, 67, 67

Sq. Ft. 1194 Linear Ft. 398

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐

Installed by Rowan Septic Tank

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY AWS

COMMENTS Raining - trenches are slightly wet.

CERTIFICATE OF COMPLETION BY Wesley Sparks RS. DATE 5/7/92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

14391

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Lennon Ventures Inc. DATE 4/3/92 PERMIT NO. 46-4-A-3

PHONE: Business _____ Home 845-8824

LOCATION Overcash Rd.

S.R. No. _____

SUBDIVISION NAME Pleasant Run. LOT NO. 3 SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area ~.5AC

Soil Characteristics P - c1 / C TRANSITION


Application Rate .3

Topography 2%

Depth to Water Table >48"

Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 5 @ 80' x 3'

Sq. Ft. 1200 Linear Ft. 400

Depth of Stone in Lines 12"

Water Supply: Individual ✓ Not DRILLED

Public ☐ YET

Installed by _____

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Wesley Sparks RS.

COMMENTS Trenches on slope contours; No deeper than 36" to trench bottom.

70, 67, 60, 67 OK - 5/4/92 (Rain)

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold