4750-918-6208
97-5833

12354

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Graham Enterprises DATE Feb. 4, '91 PERMIT NO. 46-A-54

PHONE: Business _____ Home _____

LOCATION 1001 NR 2378 (Overcash) on left just before jct. w/ Weathers Creek Rd. (2379) S. R. No. _____

SUBDIVISION NAME Pheasant Run Ph. 1 LOT NO. ~~20~~ 17 SECTION OR BLOCK NO. _____

OW

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site ~~Suitable~~ PS Yes (✓) No ( )

Character & Porosity of Soil ps clay
Percolation Rate 2, 4
Topography 2-4%
Depth to Water Table 4'+
Rock or other impervious formations none obs

Lot Area 29,000 ft²

_____ Basement with Plumbing _____ Basement without Plumbing ___✓___ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by James Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY WS

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature] / EHC DATE 2-4-91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold