4750-98-0320

14145

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Crown Ventures Inc. DATE 3/30/92 PERMIT NO. 46-4-A-12

PHONE: Business 845-8824 Home

LOCATION Overcash Rd; Oswalt Unity TR on Overcash, ~ 1/2 mile on (L) in field

SUBDIVISION NAME Pleasant Run S.R. No.

LOT NO. 12 SECTION OR BLOCK NO.

House ☑ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 3/4 Ac.

Soil Characteristics P - C (S - SP - WK)


Application Rate P .3

Topography P 4-8%

Depth to Water Table S > 48"

Rock or other impervious formations S None observed

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4 @ 100' x 3'

Sq. Ft. 1200 Linear Ft. 400

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐

Installed by Rowan Septic Tank

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed:

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY DRH

COMMENTS Wet rainy day - soil not saturated when covering operation begun. Keep driveway off septic tank and drainfield

CERTIFICATE OF COMPLETION BY Wesley Sparks RS. DATE 3/30/92

EXISTING SYSTEM CHECKED BY DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold