4750-98-1230

14146

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Crown Ventures Inc. DATE 3/25/92 PERMIT NO. 46-4-A-13

PHONE: Business 845-8824 Home

LOCATION 115-21N TR Oswell Amity TR Overcash Rd. ~1/2 mile on left

SUBDIVISION NAME Pleasant Run S.R. No.

LOT NO. 13 SECTION OR BLOCK NO.

House ☑ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Washing Machine Yes ☑ No ☐

Lot Area 3/4 AC.


Soil Characteristics P-1-C (A-SP)

Application Rate .3

Topography 4-8%

Depth to Water Table >48"

Rock or other impervious formations none observed



Plot of System (Not to Scale) OVERCASH RD

☐ Basement with Plumbing ☐ Basement without Plumbing ☑ No Basement ☑ Crawl Space

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4 @ 100' x 3'

Sq. Ft. 1200 Linear Ft. 400

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐

Installed by Rawson Septic Tank

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed:

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY

COMMENTS Keep driveway off septic tank system.

CERTIFICATE OF COMPLETION BY Wesley Sparks RS. DATE 3/25/92

EXISTING SYSTEM CHECKED BY DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold