HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: William Scott Feimster OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE: 1 acre
LOCATION OF SITE: Bear Tree Rd
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(i) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	Linear H to 6%	0 to 4	L	GR		.1942 WETNES CONDITION - N/A
		4 to 26	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		36 to 48	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	Linear H90	0 to 6	L	GR		.1942 WETNES CONDITION - N/A
		6 to 48	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
						.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
3	Linear H90	0 to 6	L	GR		.1942 WETNESS CONDITION - N/A
		6 to 30	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		30 to 36	CL	weak SBK	1:1	.1944 RESTRICTIVE HORIZON - N/A
		36 to 48	B/C	Transition		.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) ✓ SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) SYSTEM TYPE Conv. Gravity
EVALUATED BY: OTHER(S) PRESENT: William Scott Feimster
COMMENTS:

DRAFT