IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 14588O PIN# 4751170303 DATE 10-23-07

OWNER OR APPLICANT Kelly Custom Builders PHONE: Business 704-664-2115 Home

ADDRESS Box 3276 Mooresville NC 28117

LOCATION Oswalt Amity Rich Fld Haven

SUBDIVISION Kelly Farms BLOCK / SECTION 3 LOT 21 LOT AREA .75 SITE CLASS. B5 DESIGN FLOW 360 L.T.A.R. +3

Septic Tank: 1000 Gallons; STB FDR Date 4-4-07

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields Square Feet 1200 Linear Feet 300

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36.4 Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 25% Conv.

Repair System Description: 30% Low Pro

Maintenance Agreement Required: ☐ Yes ☐ No

☑ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☑ Individual ☐ Public ☐ Community

☐ Gravity ☐ Pressure ☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Comments:/Conditions:

- Install. as Contour
- Maintain all setback
- Maintain from well

INITIAL SITE SKETCH

AS BUILT SKETCH

Yellow Surf – Tote

Septic Marker

Fieldhaven

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Michelle Kelley date

Improvement Permit by: Kenneth Cook date 10-23-07

Authorization to Construct by: Kenneth Cook date 10-23-07

Installed by: Hyde Inda

Operation Permit by: Kenneth Cook date 12-19-07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK