DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: 41 3A 12
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RICHARD K GREEN OWNER: ✓ AGENT: ___ PHONE: 528-0183
ADDRESS: 102 RAINWOOD DR APPLICATION DATE: ___ DATE EVALUATED: ___
TROUTMAN, NC. PROPOSED FACILITY: 3BD - 2BA MOBILE HOME
PROPERTY SIZE: ___
LOCATION OF SITE: SUMMERTEE
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	S 3%-4%	0-5	wk GRN / s l	1:1	P	P	S	P	.3
		6-11	wk GR-s sbk / c	1:1	P	P	P		
		12-24	wk sbk / c	~1:1	P	P	P	P	
		25-33	wk sbk / c	~1:1	P	P	~~P~~ I	II	P
		34-36+	sbk / sc	~1:1 (Mottles) P ↓		P	P	II	.20-.25
2									
3									
4									
5									

AVAILABLE SPACE (.1945) P SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .2
EVALUATED BY: Sparks OTHER(S) PRESENT: ___
COMMENTS: Below 24" TRANSITION + clay - glaying & 5% later