DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 2 of 2
PROPERTY ID #: 4751-23-2160
COUNTY: Pender

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Scottie Brown
ADDRESS:
PROPOSED FACILITY: SFR
PROPOSED DESIGN FLOW (.1949): 240gpd
LOCATION OF SITE:
WATER SUPPLY: • Private • ~~Public~~ • Well • Spring • Other
EVALUATION METHOD: • Auger Boring • Pit • Cut

APPLICATION DATE 26Oct11
DATE EVALUATED: 19Oct11
PROPERTY SIZE: 0.75ac±
PROPERTY RECORDED:
TYPE OF WASTEWATER: • Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
5	L/Head 6%	0-10	apl L	vfr lsap	NA	48	NA	NA	PS 0.3
		10-20	ssic/scl	fr lsap					
		20-48	ssic/c	fr lsap					
6	L/Head 6%	0-9	gr lsl	vfr lsap	NA	48	NA	NA	PS 0.3
		9-17	ssic/scl	fr lsap					
		17-48	ssic/c	fr lsap					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	III
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NA
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: TCH
OTHER(S) PRESENT:

COMMENTS: