HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: William Squailia OWNER: AGENT: PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
_____ PROPOSED FACILITY: _____
_____ PROPERTY SIZE: _____
LOCATION OF SITE: _____
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	Linear 10%	0 to 4	L	GR		.1942 WETNES CONDITION - N/A
		4 to 24	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		24 to 36	C	ABK	1:1	.1944 RESTRICTIVE HORIZON - N/A
		36 to 48	C	ABK	mixed	.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
2	Linear 8%	0 to 4"	L	GR		.1942 WETNES CONDITION - N/A
		4 to 30	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		30 to 36	C	ABK	1:1	.1944 RESTRICTIVE HORIZON - N/A
		36 to 48	C	ABK	mixed	.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3	Linear 6%	0 to 3	L	GR		.1942 WETNESS CONDITION - Chroma 3 to 6
		3 to 24	C	SBK	1:1	.1943/.1956 SAPROLITE - 42"
		24 to 36	C	ABK	1:1	.1944 RESTRICTIVE HORIZON - 42"
		36 to 42	C	ABK	mixed	.1948 PROFILE CLASSIFICATION - PS
		42"+	Saprolite			PROFILE LTAR - .3
4	slight Head Slope	0 to 4	L	GR		.1942 WETNESS CONDITION - N/A
		4 to 25	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		25 to 36	C	ABK	1:1	.1944 RESTRICTIVE HORIZON - N/A
		36 to 48	Saprolite			.1948 PROFILE CLASSIFICATION - 36"
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) _____ SITE CLASSIFICATION (.1948): _____ SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) _____ SYSTEM TYPE _____
EVALUATED BY: R.C. moore OTHER(S) PRESENT: William Squailia
COMMENTS: _____

DRAFT