IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Blake Pratt DATE 12-5-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-77 T. Amity Church # 2342 - Cross Creek TR on Vic Rd before Rd # 2367 S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (4) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (4)	
Auto. Dishwasher	Yes (4)	No ( )	
Auto. Wash. Machine	Yes (4)	No ( )	
Site Suitable	Yes (4)	No ( )	

Lot Area Adequate

Character & Porosity of Soil Red Clay
Percolation Rate Good
Topography Some Terrain
Depth to Water Table 4ft
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (4)
Public ( )

Installed by Hobbs Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Foard DATE 1/5/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold