DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Doug Pont OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	linear 6%	0 to 48	C SGK	S SAP	PS	PS	PS	PS	.3
2	linear 6%	0 to 48	C SGK	S SAP	PS	PS	PS	PS	.3
3									
4									
5									

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY R.C. Moore OTHER(S) PRESENT: Mrs Doug Pont
COMMENTS:

0018896