154 Arthurs Rd.

4751501642

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Brady Holland DATE 2-10-82 PERMIT NO. 16

PHONE: Business _____ Home _____

LOCATION 21 North TR 1001 TR 2420 .2 Mile on R
Oswalt Amity Arthurs

_____ S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other Existing System

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil		
Auto. Dishwasher	Yes ( )	No (X)	Percolation Rate		Existing
Auto. Wash. Machine	Yes (X)	No ( )	Topography		System
Site Suitable	Yes (X)	No ( )	Depth to Water Table		
Lot Area Existing			Rock or other impervious formations		

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System
Proposed Shop
(Not to Scale)

Size of Tank Existing Gals.

Nitrification Field:
No. of Lines Existing
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____

Water Supply: Individual (X)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Existing system working ok at date of inspection - Tank located under porch -

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Fred Clemmer DATE 2-10-82

CONSTRUCTION MUST COMPLY WITH ALL OTH

Permit is VOID if any unauthorized changes are made in installation Improvements Permit.

The location of the proposed Shop addition does not appear to impact the existing septic system.
**NOTE: Shall be min. 5' from septic system

Andy Melville REHS
Date: 12-20-11
ICHD-Environmental Health Division

Health Dept. Copy: White Inspection Dept. Copy: