IREDELL COUNTY HEALTH DEPARTMENT

THIS PERMIT REPLACES PREVIOUS PERMITS # 106072 & 106073

STATESVILLE 704-878-5305 (c1) MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

(1)

PERMIT# 114017 PIN# 4751-62-3131 2057 DATE 7-26-03

OWNER OR CONTRACTOR SHIRLEY J. COLLINS PHONE: Business Home 704-660-6559

ADDRESS 251 SOUTH BROAD STREET MOORESVILLE NC 28115

LOCATION US 21 SOUTH, TL OSWALT AMITY ROAD, ON LEFT JUST BEFORE ARTHURS ROAD

SUBDIVISION BLOCK / SECTION LOT LOT AREA 3.024 ACRES SITE CLASS PS DESIGN FLOW 625 L.T.A.R. 0.25 GPD/FT²

Septic Tank: 1500 Gallons; STB 101 Date 12-3-04

Grease Tank: 1500 Gallons; STB 101 Date 12-11-04

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet Est. TO 2500 Linear Feet 640

No Lines EIGHT Trench Width 36" Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair System Type: I, II, (III), IV, V, VI

System Description: 25% REDUCTION, GRAVITY

Repair System Description: 25% REDUCTION, GRAVITY

Maintenance Agreement Required: ☐ Yes ☑ No

☐ House/Mod. Home No. Bedrooms

☐ Mobile Home No. Bathrooms

☐ Business No. Employees

☑ Other CHURCH @ 125 SEATS @ 5 GPD/SEAT

Water Supply: ☐ Individual ☑ Public ☐ Community

☑ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Comments:/Conditions: (2) INSTALL 25% REDUCTION SYSTEM IN EIGHT EQUAL 80 FT. LINES AT 36 INCHES DEEP (2) INSTALL SUBSURFACE INTERCEPT DRAINAGE DITCH AT LOCATION SHOWN MINIMUM 48" DEEP. (3) ALL KITCHEN DRAINS PLUMB INTO GREASE TRAP

Comments:/Conditions: (4) ALL PROPERTY SHOWN ON SITE SKETCH TO BE RECOMBINED INTO ONE PARCEL PRIOR TO ISSUANCE OF AUTHORIZATION TO CONSTRUCT

INITIAL SITE SKETCH

SEE ATTACHED SHEET FOR SITE SKETCH

AS BUILT SKETCH

SEPTIC TANK & GREASE TRAP INSTALLED WITH RISERS USING "TUFTITE" FILTER

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 8/5/03 Installed by: DALE WINGLER

Improvement Permit by: STEVE HEDRICK date 7-26-03 Operation Permit by: STEVE HEDRICK date 5-23-05

Authorization to Construct by: STEVE HEDRICK date 10-1-04 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

PERMIT # 114017 SITE SKETCH

% SHIRLEY J. COLLINS
STRAIT WAY MISSIONARY BAPTIST CHURCH
PIN # 4751-62-3131
SCALE: 1" = 60'

