DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 16660
PROPERTY RECORDED: N
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MILAS GAMBLE OWNER: AGENT: ✓ PHONE:
ADDRESS: R+ 507 R+ 1 APPLICATION DATE: 7/15 DATE EVALUATED: 7/15
TROUTMAN, NC. PROPOSED FACILITY: 3-2 MOBILE HOME
PROPERTY SIZE: 106' X 200'
LOCATION OF SITE: OVERCASH RD. 115 N TR OS-AMITY TR OVERCASH, 2ND TRAILER ON (L)
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	3%	0-10	0 sg / GL	1:1	WSO-WPO	No	S		
		11-16	1 sg / cl	1:1	WSO-WPO	No	S		
		17-28	3 sbk / c	1:1	WS-WPS	No	P		
		29-41	3 WK sbk / c	1:1	WS-WP	No	P		
		42-46	2 sbk / c	1:1	WSS-WPS	No	P		.25-.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945) P SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .25-.3
EVALUATED BY: Sparks OTHER(S) PRESENT: MILAS GAMBLE
COMMENTS: