IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 12787B PIN# 4751 97 2516 4751-97-0386 DATE 5-17-05

OWNER OR CONTRACTOR MICHAEL CRIMI PHONE: Business 704-400-4285 Home 704-655-0330

ADDRESS ~~[illegible]~~ 20358 STERLING BAY LN WEST CORNELIUS, NC 28031

LOCATION 77 SOUTH @ AMITY HILL @ STARLIGHT, HOUSE ON VIEW END / SYSTEM IS OFF-SIGHT

SUBDIVISION _____ BLOCK / SECTION _____ LOT _____ LOT AREA 17.366AC SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .4

Septic Tank: 1000 Gallons; STB 1000T Date 9-14-05

Pump Tank: 1000 Gallons; PT 274 Date 9-19-05

Pump Make: ZOELLER Model 140-C Serial No. 140-0002

Nitrification Field: No. Fields 1 Square Feet EA= 900 Linear Feet 150'

No Lines 3X50' Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair System Type: I, II, III, (IV), V, VI

System Description: LP 50% REDUCTION

Repair System Description: SAME

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 2

☐ Business No. Employees ____

☐ Other _____

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☒ Individual ☐ Public ☐ Community WELL

Comments:/Conditions: ① B4 INSTALLATION, SMOOTH OUT CONTOURS UNIFORMLY AS DRAWN ② SYSTEM AREA IS FLAGGED ③ MAINTAIN SEEDING + FOLLOWS RULES FOR PROPER CREEK

Comments:/Conditions: 4" in CROSSING - Supply is 2 3/4" DEEP FOR VEHICULAR TRAFFIC 63' FROM CREEK TO TANKS 1-1000 TANKS + supply across culvert 10-06 LC

INITIAL SITE SKETCH CROSSING.

SEE ATTACHED SITE PLAN BY Samuel ASHLEY ROLLINS, LSS

FAST TRACK PERMIT

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date _____ Installed by: SELF INSTALLED MICHAEL CRIMI

Improvement Permit by: _____ date 5-17-05 Operation Permit by: _____ date 8-24-06

Authorization to Construct by: _____ date 5-17-05 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK