J.C. Moore
Certified Operator #985357
Maintenance Report Form

Name and Location of System
Michael Crimi
137 Starlight Rd
Statesville, N.C.
28677

Date of Inspection
2-12-07

Permit Number
127878

County
Iredell

System Classification
IV - A

Name and Address of "ORC"
J.C. Moore
1227 Troutman Drive
Statesville, NC 28625

Name and Address of Owner
Same

Phone: (704) 873-2171

Phone: 704 400 4285

Legend: S-Satisfactory, M-Marginal, U-Unsatisfactory
N-not evaluated, N/A-Nonapplicable

SEPTIC TANK AND PUMP TANK
- S Risers accessible
- S Signs of Infiltration
- S Structurally Sound
- S Landscape Position
- S Filter Cleaned

PUMP
- yes Pump present and operating
  - 20 Design GPM
  - 20 Actual GPM
  - 100 % Efficiency
- yes High water alarm operating properly
- S Pipework in good condition
- S Control panel in good condition
- S Control floats operating properly
- S Straps and float tree
- S Effluent free and clear of solids

DRAIN FIELD
- S No effluent surfacing
- S Surface water diverted
- S Line cover maintained properly
- S Protected from traffic
- S Distribution devices operating properly
- S Repair area reserved

Date 2-12-07

LOW PRESSURE PIPE SYSTEM
- S Turnups, cleanouts, valves located and protected
- S Laterals free of excess solids
- yes Laterals flushed

Pressure Heads

	Design head	Adjusted head
Line 1	2'	2'
Line 2	2'	2'
Line 3	2'	2'
Line 4		

COMMENTS

Compliant ✓ Noncompliant ___
Signature J.C. Moore

J.C. Moore
Certified Operator #985357
Maintenance Report Form

Name and Location of System
Michael Crimi
137 Starlight Rd
Statesville, N.C.

Date of Inspection
8-8-07

Permit Number
127878

County
Iredell

System Classification
IV - A

Name and Address of "ORC"
J.C. Moore
1227 Troutman Drive
Statesville, NC 28625

Name and Address of Owner
Same

Phone (704) 873-2171

Phone: 704 400 4285

Legend: S-Satisfactory, M-Marginal, U-Unsatisfactory
N-not evaluated, N/A-Nonapplicable

SEPTIC TANK AND PUMP TANK
- S Risers accessible
- S Signs of Infiltration
- S Structurally Sound
- S Landscape Position
- S Filter Cleaned

PUMP
- YES Pump present and operating
- 20 Design GPM
- 20 Actual GPM
- 100 % Efficiency
- YES High water alarm operating properly
- S Pipework in good condition
- S Control panel in good condition
- S Control floats operating properly
- S Straps and float tree
- S Effluent free and clear of solids

DRAIN FIELD
- S No effluent surfacing
- S Surface water diverted
- S Line cover maintained properly
- S Protected from traffic
- S Distribution devices operating properly
- S Repair area reserved

Date 8-8-07

LOW PRESSURE PIPE SYSTEM
- S Turnups, cleanouts, valves located and protected
- S Laterals free of excess solids
- YES Laterals flushed

Pressure Heads

	Design head	Adjusted head
Line 1	2'	2'
Line 2	2'	2'
Line 3	2'	2'
Line 4		

COMMENTS

Compliant ✓ Noncompliant ____

Signature J. C. Moore

J.C. Moore
Certified Operator #985357
Maintenance Report Form

Name and Location of System

Michael Crimi
137 Starlight Rd
Statesville, N.C. 28677

Date of Inspection

2-5-08

Permit Number

127878

County

Iredell

System Classification

IV - A

Name and Address of "ORC"
J.C. Moore
1227 Troutman Drive
Statesville, NC 28625

Name and Address of Owner

Same

Phone: (704) 873-2171

Phone: 704 400 4285

Legend: S-Satisfactory, M-Marginal, U-Unsatisfactory
N-not evaluated, N/A-Nonapplicable

SEPTIC TANK AND PUMP TANK
- S Risers accessible
- S Signs of Infiltration
- S Structurally Sound
- S Landscape Position
- S Filter Cleaned

PUMP
- YES Pump present and operating
  - 20 Design GPM
  - 20 Actual GPM
  - 100 % Efficiency
- YES High water alarm operating properly
- S Pipework in good condition
- S Control panel in good condition
- S Control floats operating properly
- S Straps and float tree
- S Effluent free and clear of solids

DRAIN FIELD
- S No effluent surfacing
- S Surface water diverted
- S Line cover maintained properly
- S Protected from traffic
- S Distribution devices operating properly
- S Repair area reserved

COMMENTS

Compliant ✓ Noncompliant ___
Signature J.C. Moore

Date 2-5-08

LOW PRESSURE PIPE SYSTEM
- S Turnups, cleanouts, valves located and protected
- S Laterals free of excess solids
- YES Laterals flushed

Pressure Heads

	Design head	Adjusted head
Line 1	2'	2'
Line 2	2'	2'
Line 3	2'	2'
Line 4	___	___

J.C. Moore
Certified Operator #985357
Maintenance Report Form

Name and Location of System
Michael Crimi
137 Starlight Rd
Statesville N.C.
28677

Date of Inspection
8-25-08

Permit Number
127878

County
Iredell

System Classification
IV - A

Name and Address of "ORC"
J.C. Moore
1227 Troutman Drive
Statesville, NC 28625

Name and Address of Owner
Same

Phone: (704) 873-2171

Phone: 704 400 4285

Legend: S-Satisfactory, M-Marginal, U-Unsatisfactory
N-not evaluated, N/A-Nonapplicable

SEPTIC TANK AND PUMP TANK
S Risers accessible
S Signs of Infiltration
S Structurally Sound
S Landscape Position
yes Filter Cleaned

PUMP
yes Pump present and operating
20 Design GPM
20 Actual GPM
100 % Efficiency
yes High water alarm operating properly
S Pipework in good condition
S Control panel in good condition
S Control floats operating properly
S Straps and float tree
S Effluent free and clear of solids

DRAIN FIELD
S No effluent surfacing
S Surface water diverted
S Line cover maintained properly
S Protected from traffic
S Distribution devices operating properly
S Repair area reserved

COMMENTS

Compliant ✓ Noncompliant ___
Signature J.C. Moore

Date 8-25-08
LOW PRESSURE PIPE SYSTEM
S Turnups, cleanouts, valves located and protected
S Laterals free of excess solids
yes Laterals flushed
Pressure Heads

	Design head	Adjusted head
Line 1	2'	2'
Line 2	2'	2'
Line 3	2'	2'
Line 4	___	___

J.C. Moore
Certified Operator #985357
Maintenance Report Form

Name and Location of System

Michael Crimi
137 Starlight Rd
Statesville N.C.
28677

Date of Inspection

2-2-09

Permit Number

127878

County

Iredell

System Classification

IV-A

Name and Address of "ORC"

J.C. Moore
1227 Troutman Drive
Statesville, NC 28625

Phone: (704) 873-2171

Name and Address of Owner

Same

Phone: 704 400 4285

Legend: S-Satisfactory, M-Marginal, U-Unsatisfactory
N-not evaluated, N/A-Nonapplicable

SEPTIC TANK AND PUMP TANK

S Risers accessible
S Signs of Infiltration
S Structurally Sound
S Landscape Position
Yes Filter Cleaned

PUMP

Yes Pump present and operating
20 Design GPM
20 Actual GPM
100 % Efficiency
Yes High water alarm operating properly
S Pipework in good condition
S Control panel in good condition
S Control floats operating properly
S Sumps and float free
S Effluent free and clear of solids

DRAIN FIELD

S No effluent surfacing
S Surface water diverted
S Line cover maintained properly
S Protected from traffic
S Distribution devices operating properly
S Repair area reserved

Date 2-2-09

LOW PRESSURE PIPE SYSTEM

S Turnups, cleanouts, valves located and protected
S Laterals free of excess solids
Yes Laterals flushed

Pressure Heads

	Design head	Adjusted head
Line 1	2'	2'
Line 2	2'	2'
Line 3	2'	2'
Line 4		

COMMENTS

Compliant ✓ Noncompliant ___

Signature J.C. Moore

J.C. Moore
Certified Operator #985357
Maintenance Report Form

Name and Location of System

Michael Crimi
137 Starlight Rd
Statesville, N.C.
28677

Date of Inspection

8-21-09

Permit Number

17878

County

Iredell

System Classification

IV - A

Name and Address of "ORC"
J.C. Moore
1227 Troutman Drive
Statesville, NC 28625

Phone: (704) 873-2171

Name and Address of Owner

Same

Phone: 704 400 4785

Legend: S-Satisfactory, M-Marginal, U-Unsatisfactory
N-not evaluated, N/A-Nonapplicable

#1

SEPTIC TANK AND PUMP TANK
- S Risers accessible
- S Signs of infiltration
- S Structurally Sound
- S Landscape Position
- NE Filter Cleaned

PUMP
- YES Pump present and operating
  - 26 Design GPM
  - 28 Actual GPM
  - 100 % Efficiency
- YES High water alarm operating properly
- S Pipework in good condition
- S Control panel in good condition
- S Control floats operating properly
- S Straps and float free
- S Effluent free and clear of solids

DRAIN FIELD
- S No effluent surfacing
- S Surface water diverted
- S Line cover maintained properly
- S Protected from traffic
- S Distribution devices operating properly
- S Repair area reserved

Date 8-21-09

LOW PRESSURE PIPE SYSTEM
- S Turnups, cleanouts, valves located and protected
- S Laterals free of excess solids
- YES Laterals flushed

Pressure Heads

	Design head	Adjusted head
Line 1	2'	2'
Line 2	2'	2'
Line 3	2'	2'
Line 4		

COMMENTS

Compliant ✓ Noncompliant ___

Signature J.C. Moore

MOORE'S ENVIRONMENTAL SERVICES
1227 TROUTMAN DRIVE
STATESVILLE, NC 28625
HOME: (704) 873-2171
CELL: (704) 902-1122 FAX: (704) 873-9928

Dear Michael Crimi :

According to my records, your Type IV-A septic system at 1307 Starlight Rd Statesville is past due for a renewal on the maintenance contract for the time period of August 2009 to August 2010.

I will need to be contacted by you if you would like to renew your maintenance contract with my company. If I don't hear from you by March 31, 2010, I will assume you have made other arrangements and no longer need my services.

According to the North Carolina Department of Environmental Health law #15A.NC, Admin. Code #18A.1961, I am required to notify the Iredell Health Department that I am no longer the operator for your system if you choose not to renew with my company.

Thank you for your past business and hopefully we can continue to do business in the future.

Sincerely,

J. C. Moore
NC Registered Sanitarian (Cert. #372)
Subsurface System Operator (Cert. #985357)
NC Onsite Wastewater Inspector (Cert. #12331)