12237

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas H. Bass DATE 12-18-90 PERMIT NO. SD-A-67

PHONE: Business _____ Home _____

LOCATION I-77 S TL on Amity Hill Rd Cross Creek 1st mH on left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )


Lot Area 1.18 acres

Character & Porosity of Soil Sandy clay loam
Percolation Rate 4
Topography Slight
Depth to Water Table 10 ft
Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement

Size of Tank 1500 (Fem) Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public ( )



Plot of System

Installed by A&A Enterprises

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: Smooth area over drain lines & Sew back with Grass

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 12-26-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold