DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET ____ OF ____

PROPERTY I.D.#: ____
DATE: 2/20/96
COUNTY: Iredell

Lot # 2

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Old Towne MH
ADDRESS: ____
OWNER / AGENT: ____ PHONE: ____
APPLICATION DATE: ____ DATE EVALUATED ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: ____
WATER SUPPLY: On-site Well ____ Comm. Well ____ Public ____ Other ____ EVAL. METHOD: Auger Boring ____ Pit: ____ Cut ____

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	2-4%	0-12	SCL	Gr	Fri			.1942 Wetness Cond. -
		12-36	C	SBK	FI			.1943 Depth/.1956 Sapr. -
		36-48	Cl	WSBK	Fri - Transition Zone			.1944 Restrictive Hori. -
								.1948 Profile Class. - PS
								Profile LTAR - .3 gpd/ft²
2	2-4%	0-6	SC	Gr	Fri			.1942 Wetness Cond. -
		6-10	SCL	Gr	Fri			.1943 Depth/.1956 Sapr. -
		10-34	C	SBK	FI			.1944 Restrictive Hori. -
		34-48	Cl	WSBK	Fri - Transition Zone			.1948 Profile Class. - PS
								Profile LTAR - .3 gpd/ft²
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) 1200 OTHER FACTORS (.1946) ____ SITECLASSIFICATION (.1948) PS

SYSTEM TYPE Gravity Conventional LONG-TERM ACCEPTANCE RATE(S) .3 gpd/ft²

EVALUATED BY: Brady Freeman/Jack Moore OTHER(S) PRESENT: ____

COMMENTS: ____