HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Susan Benfield OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 12-15-94
PROPOSED FACILITY: Single family
PROPERTY SIZE: 197 acres
LOCATION OF SITE:
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	Linear 4%	0 to 8"	L	GR		.1942 WETNES CONDITION	N/A
		8 to 48	C	~~SBK~~ ABK	1:1	.1943/.1956 SAPROLITE	N/A
						.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.3
2	Linear 4%	0 to 6	L	GR		.1942 WETNES CONDITION	N/A
		6 to 30	C	~~SBK~~	1:1	.1943/.1956 SAPROLITE	N/A
		30 to 48	CL	~~weak SBK~~ ABK	1:1	.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.3
3		0 to 6	L	GR		.1942 WETNESS CONDITION	N/A
		6 to 30	C	~~SBK~~	1:1	.1943/.1956 SAPROLITE	N/A
		30 to 48	CL	~~weak SBK~~ ABK	1:1	.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.3
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): ~~PS~~ PS SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) SYSTEM TYPE Conv Gravity
EVALUATED BY: R.C. Moore OTHER(S) PRESENT: Susan Benfield
COMMENTS:

DRAFT