IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

WNER OR CONTRACTOR Wade Hendrix DATE 2 Dec 75 PERMIT NO.

HONE: Business Home

OCATION Hwy 70 E. to Mobile Ct. Rd. Cross Creek 1st dirt strt to Rt two trailers on Rt

S. R. No.

UBDIVISION NAME Henderson MHP LOT NO. 243 SECTION OR BLOCK NO.


ouse ( ) Mobile Home ( ) Business ( ) Other 2 mobile Homes

o. Bedrooms No. Bathrooms

arbage Disposal Unit	Yes ( )	No (✓)	
uto. Dishwasher	Yes ( )	No (✓)	
uto. Wash. Machine	Yes (✓)	No ( )	
ite Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Cecil Cly
Percolation Rate 60
Topography Slope to driveway
Depth to Water Table ok
Rock or other impervious formations ok

ot Area



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1250 Linear Ft. 500
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Gentry

MPROVEMENTS PERMIT BY

OMMENTS:

ERTIFICATE OF COMPLETION BY Will Howard DATE 2 Dec 75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold