IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

WNER OR CONTRACTOR Wade Henderson DATE 2 Dec 75 PERMIT NO.

HONE: Business Home

OCATION Hy 70 E. to Mitch Cl. Rd. Cross Creek 1st dirt street to right two trailers on left. S. R. No.

UBDIVISION NAME Henderson MHP LOT NO. 2+3 SECTION OR BLOCK NO.


ouse ( ) Mobile Home ( ) Business ( ) Other 2 mobile homes

o. Bedrooms No. Bathrooms

arbage Disposal Unit	Yes ( )	No (✓)	
uto. Dishwasher	Yes ( )	No (✓)	
uto. Wash. Machine	Yes (✓)	No ( )	
ite Suitable	Yes (✓)	No ( )	

ot Area

Character & Porosity of Soil Cecil Clay
Percolation Rate 60
Topography Slope to Swamp
Depth to Water Table 4'
Rock or other impervious formations none



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1250 Linear Ft. 500
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Young

MPROVEMENTS PERMIT BY

OMMENTS:

ERTIFICATE OF COMPLETION BY W M Howard DATE 2 Dec 75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold